

スウェーデン式サウンディング試験結果

平成23年11月11日
No.05

Sweden-Pro様邸
東京都渋谷区千駄ヶ谷3丁目地先

Wsw (kN)	半回転数 (回)	Nsw (回)	記事 (貫入状況)	土質	深度 (m)	換算 N値	換算 支持力	支持力qa (kN/m ²)			
								0	50	100	150
1.00	2.0	8.0		粘性盛土	0.25	3.4	42.5				
1.00	3.0	12.0		ローム	0.50	3.6	45.0				
1.00	3.0	12.0		〃	0.75	3.6	45.0				
1.00	3.0	12.0		〃	1.00	3.6	45.0				
1.00	2.0	8.0		〃	1.25	3.4	42.5				
1.00	3.0	12.0		〃	1.50	3.6	45.0				
1.00	2.0	8.0		〃	1.75	3.4	42.5				
1.00	2.0	8.0		〃	2.00	3.4	42.5				
1.00	3.0	12.0		〃	2.25	3.6	45.0				
1.00	3.0	12.0		〃	2.50	3.6	45.0				
1.00	3.0	12.0		〃	2.75	3.6	45.0				
1.00	3.0	12.0		〃	3.00	3.6	45.0				
1.00	2.0	8.0		〃	3.25	3.4	42.5				
1.00	0.0	0.0	ユックリ	粘性土	3.50	3.0	30.0				
1.00	0.0	0.0	〃	〃	3.75	3.0	30.0				
1.00	0.0	0.0	〃	〃	4.00	3.0	30.0				
1.00	0.0	0.0	〃	〃	4.25	3.0	30.0				
1.00	3.0	12.0		〃	4.50	3.6	45.0				
1.00	7.0	28.0		〃	4.75	4.4	55.0				
1.00	9.0	36.0		〃	5.00	4.8	60.0				
1.00	5.0	20.0		〃	5.25	4.0	50.0				
1.00	10.0	40.0		〃	5.50	5.0	62.5				
1.00	12.0	48.0		〃	5.75	5.4	67.5				
1.00	7.0	28.0		〃	6.00	4.4	55.0				
1.00	13.0	52.0		〃	6.25	5.6	70.0				
1.00	15.0	60.0		〃	6.50	6.0	75.0				
1.00	14.0	56.0		〃	6.75	5.8	72.5				
1.00	12.0	48.0		〃	7.00	5.4	67.5				
1.00	21.0	84.0		〃	7.25	7.2	90.0				
1.00	15.0	60.0		〃	7.50	6.0	75.0				
1.00	18.0	72.0		砂質土	7.75	6.8	54.6				
1.00	24.0	96.0		〃	8.00	8.4	67.5				
1.00	18.0	72.0		〃	8.25	6.8	54.6				
1.00	25.0	100.0		〃	8.50	8.7	69.6				
1.00	16.0	64.0		〃	8.75	6.3	50.3				
1.00	24.0	96.0		〃	9.00	8.4	67.5				
1.00	27.0	108.0		〃	9.25	9.2	73.9				
1.00	18.0	72.0		〃	9.50	6.8	54.6				
1.00	18.0	72.0		〃	9.75	6.8	54.6				
1.00	42.0	168.0		〃	10.00	13.3	106.1				